

McHenry County Government Center
Adam Letendre, Director of Purchasing
Purchasing Department
Administration Building Room 200
Woodstock, IL 60098
Phone: 815-334-4818
Fax: 815-334-4680

April 17, 2018

ADDENDUM #1

**Bid #18-26 AIR FILTERS
DUE April 23, 2018 at 2:00PM (CST)**

Additions & Clarifications to Bid

Question #1:	The question I have pertains to item number 46 on page 9 of the document. The size given is a 24x24x11-1/2. What type of filter is this? Can more information be provided?
Response #1:	This is a specific filter used in the negative pressure exhaust fan in the medical pod of the Jail. We install one per year. Currently installed: Purolator Ultra Cell - UCGLV97 24024012XBU GND 00 00 24 X 24 X 11.5

**ALL OTHER TERMS AND CONDITIONS OF THE BID REMAIN
THE SAME.**