

McHenry County Government Center
Adam Letendre, Director of Purchasing
Administration Building Room 200
Woodstock, IL 60098

June 11, 2019

ADDENDUM #2

**Bid #19-20 Equipment & Labor to Replace Two (2) Uninterruptible Power Supplies
Due June 19, 2019 by 2:00PM (CST)**

Additions & Clarifications to BID

- Question #1:** Is there a loading dock at the facility for delivery of equipment or is a lift gate needed for delivery?
Response: Yes; there is a loading dock
- Question #2:** Are there any loading dock restrictions at each facility?
Response: There is only one facility and loading dock.
- Question #3:** How far is each UPS room from the loading dock at each facility?
Response: There is only one facility. One unit is on the first floor, approx. 250 feet, ramp involved. Second unit on 3rd floor, approx. 150 feet, ramp involved.
- Question #4:** Is there an elevator for use if the UPS room is not on the 1st floor?
Response: Yes
- Question #5:** Is any floor protection needed to move the equipment?
Response: We do not want our linoleum floors to be marked or scratched.
- Question #6:** Is there a pallet jack at each site we can use for the moving of equipment?
Response: Vendor must bring their own equipment to remove existing and install new equipment.
- Question #7:** Is there room for storage of equipment for a day or two at each loading dock?
Response: No
- Question #8:** Why are you replacing the units?
Response: N/A
- Question #9:** What are the current model numbers and power supplies?
Response: Powerware 9330-20/10. Three Phase, online, single input, hardwired. Input: 208/120, Output: 28/120.
- Question #10:** Is this request for proposal limited to one bid submittal per vendor, or will you accept more than one bid from the same vendor for different manufacturers equipment?
Response: Please refer to page 7 of the bid under "SUBMITTAL: Submit one (1) bid, multiple bids will not be accepted."
- Question #11:** Can you provide a copy of the site visit sign in sheet?
Response: Attached

All Other Terms and Conditions of the Bid Remain the Same

PRE-BID/SITE VISIT SIGN-IN SHEET

Project: #19-20 Equipment & Labor to replace two Uninterruptible Power Supplies

Meeting Date: 6/19/19

Department: Sheriff Dept

Place/Room: Purchasing Conference Room

Please print and include all information

Company Name: County of McHenry

Phone: x4605

Attendee Name: Djuana Leonard

E-Mail: dmleonard@mchenrycountvil.gov

Company Name: SEPS INC

Phone: 630-380-3081

Attendee Name: Aaron Spencer

E-Mail: Aspencer@SEPS-Int.com

Company Name: Orion Electric

Phone:

Attendee Name: Jeff Battista

E-Mail: jbattista@Orion-elec.com

Company Name: BURNETT & SONS ELECTRIC

Phone:

Attendee Name: MICHAEL BURNETT

E-Mail:

Company Name: NATIONWIDE POWER

Phone:

Attendee Name: MICHAEL BURNETT

E-Mail:

Company Name: KTI ELECTRIC

Phone:

Attendee Name: KARL KLAUS

E-Mail:

Company Name: C&I POWER

Phone: 847-277-5277

Attendee Name: THOMAS LARSE

E-Mail: TL@CIPWR.com

Company Name: MEGC

Phone:

Attendee Name: OFFICER L,

E-Mail: