



McHenry County

Division of Transportation

Joseph R. Korpalski, Jr., P.E.
Director of Transportation/County Engineer

McHenry County Division of Transportation
2026 Charles J. Miller Bridge Project
Section 24-00589-00-BR

Questions & Answers
Revision #2
February 25, 2026

The following revisions have been made and questions asked during project advertisement. Answers to questions are noted below. This will be posted on MCDOT's Bid Documents page at <https://www.mchenrycountyil.gov/departments/transportation/doing-business>. Please read fully and return a signed copy of this to the email below to be eligible to bid on this project.

Question 13: Per Note 4 in the General Notes for the Traffic Control & Protection (Special) Crossover Details on Plan Sheets 24 & 25: "Temporary Pavement shall be hot-mix asphalt...."

Per the Special Provisions for Temporary Pavement (Page 5): "The contractor shall use either Portland cement concrete according to Sections 353 and 354 of the Standard Specifications or HMA according to Sections 355, 356, 406 of the Standard Specifications, and other applicable HMA special provisions as contained herein. The HMA mixtures to be used shall be specified in the plans. The thickness of the Temporary Pavement shall be as described in the plans. The contractor shall have the option of constructing either material type if both Portland cement concrete and HMA are shown in the plans.

The HMA Mix Chart on Sheet 2 of the Contract plans do not provide any HMA mix information for the temporary pavement. The contract plans and special provisions do not clearly indicate that PCC pavement is allowed. Both options are not shown in the plans – only the HMA option is referenced Thus, currently only the HMA option would be allowed.

Please clarify the requirements for Item Z0062456 TEMP PAVEMENT (i.e. HMA mix type/design/requirements, etc) if only the HMA option is required.

Please clarify both the plans and specifications if both options are allowed.

This information will be required to provide a bid price for this item of work.

Answer: The temporary pavement shall be HMA with standards that match the proposed pavement. Plan sheet 2 and Page 5 of the Specifications have been updated.

Upon receipt of this Q&A, execute and return a signed copy by email to MCDOTBidDocs@mchenrycountyil.gov . **Bids will only be accepted from Contractors who have acknowledged the above information. This does NOT need to be incorporated into the bid packet.**

Date: _____

Contractor: _____

Signed : _____